

			11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28		
			Skeem							Grupi nr.	Tarbija nimetus		kW	Iv/In	Kaabeldus							
Muudatus D	Muudatus E	Muudatus F								P0	Üldtarbijate sektsioon			63A			A					
																B						
										P1	Soojuspumba siseosa			C25	XPJ-HF C Pro 5G6		C					
										P2	Soojuspumba välisosa			C25	XPJ-HF C Pro 5G6		D					
										P3	Nõrkvoolu majajaotla BD			B16	XPJ-HF C Pro 3G2,5		E					
										P4	Fono			C10	XPJ-HF C Pro 3G1,5		F					
										P5	ATS keskus			C10	XPJ-HF C Pro 3G1,5		G					
										P6	Reserv			C10			H					
										P7	P.pesad, kilbiruum, tehnoruum			B16	XPJ-HF C Pro 3G2,5		J					
										P8	Reserv			B16			K					
										P9	P.pesad, kelder, pööning			B16	XPJ-HF C Pro 3G2,5		L					
										P10	P.pesad, trepikoda			B16	XPJ-HF C Pro 3G2,5		M					
			P11	Reserv			B16			N												
			P12	Vent. üldalad			B16	XPJ-HF C Pro 3G2,5		O												
										P												
			P13	ATS Blokeering			B10			R												
			P14	Vihmaveetorude küte			C13	XPJ-HF C Pro 3G2,5		S												
			P15	Vihmaveetorude küte			C13	XPJ-HF C Pro 3G2,5		T												
			PA1	TEMP/NIISKUSANDUR				MSK-HF 5G1,5		U												
			VV1	Välisvalgustus		0,6	C10	MCMK HF C-Pro 3x1,5		V												
			VV2	Välisvalgustus		0,5	C10	XPJ-HF C Pro 3G1,5		X												
			VV3	Reserv			C10			Y												
			HJ	juhtimine hämaraandurist				2x1,5		Z												
			Muudatus A	Muudatus B:	Muudatus C:	V1	Valg. trepikoda		0,6	C10	XPJ-HF C Pro 3G1,5		1									
V2	Valg. tehnoruum					0,6	C10	XPJ-HF C Pro 3G1,5		2												
V3	Turvavalgustus					0,6	C10	XPJ-HF C Pro 3G1,5														
V4	Valg. pööning, kelder					0,6	C10	XPJ-HF C Pro 3G1,5														