

Architectural floor plan of a building with technical specifications and dimensions.

Technical Specifications:

- külmakerke soojustus $H=100$
- EPS 120 Perimeeter
- $B=1000$
- al.KM-0.85
- paigaldada kaldega majast eemale

Dimensions and Labels:

- Overall Dimensions:** 5000 (width), 15800 (length), 15150 (total length including setbacks).
- Room Labels:** SO-1, SO-2, SO-3, SO-4.
- Structural Elements:** SO-1, SO-2, SO-3, SO-4 (rooms); SO-1, SO-2, SO-3, SO-4 (structural elements).
- Setbacks:** maapind KM-0.30, maapind KM-0.45, maapind KM-0.30.
- Other Labels:** SÕLM A, V-4, -0.10.

1. Sokli müüritis SO-1...SO-4 laduda betoon-õõnesplokkidest (min.survetugevus 18 MPa). Mõrdi mark M10 (survetugevus 10 MPa)
2. Kõik seinte SO-1...SO-3 nurgad ja liitumiskohad armeerida horisontaalselt võrguga Ø4Bp-l igas vuugis vähemalt 1 m ulatuses igas suunas. Võrgu silm BxL=155x200mm, võrgu jätkamisel ülekate vähemalt 250 mm.
3. Lisaks armeerida seinte SO-1...SO-3 esimene ja viimane kivirida sarrusvööga 2Ø10.
4. Postid SO-4 armeerida püstsarrusega Ø10 igas posti nurgas.
5. Soklimüüri SO-1...SO-4 kõik õõned täis betoneerida, betooni tugevusklass C25/30
5. R/B post P-1 valada betoonist tugevusklass C25/30 XC2, sarruse kaitsekiht c=30mm. Betoonpinna kvaliteediklass C (vastavalt juhendile BÜ4 2010).
6. Soklimüüri SO-1...SO-4 lõiked vaata joonis K-5

Muudatus	Kuupäev	Sisu	Teostaja