

SKEEM APARATUURI ANDMED	GRUPI NR.	TARBIJA	INST. VÕIMSUS	KAITSE A / A	JUHTMESTIK mm2
		Pealüüti Elektrienergiaarvesti	16.5		XPJ-HF D 5G10
	1	Soojuspumba SP kompressorid	2.44	C16	XPJ-HF D 5G4
	2	Soojuspumba SP automaatikaplokk	1.00	C16	XPJ-HF D 3G2,5
	3	Boiler	9.00	B16	XPJ-HF D 5G2,5
	4	Reserv		C16	
	5	Ringluspump P1	0.65	C6	XPJ-HF D 3G1,5
	6	Ringluspump P2	0.65	C6	XPJ-HF D 3G1,5
	7	Ringluspump P3	0.65	C6	XPJ-HF D 3G1,5
	8	Ringluspump P4	0.65	C6	XPJ-HF D 3G1,5
	9	Ringluspump P5	0.65	C6	XPJ-HF D 3G1,5
	10	Glükooli täitepump P8	0.50	C6	XPJ-HF D 3G1,5
	11	Reserv			
	12	3T ventiil	0.05	C6	XPJ-HF D 3G1,5
	13 13S1	Katuse ventilaatorid 1-0-2 ümberlüüti	0.22	C10	XPJ-HF D 5G2,5