

ÕHUHULKADE TABEL

N ^o	Nimetus	Pind m ²	S l/s	V l/s	Norm. müra tase	Süsteem	Märkus
1.KORRUS							
1	Korter	10.6	10	s	30	SV-1	+7 l/s in, +bil.
2	WC + Dušš		s	15	35	SV-1	-15 l/s üh
2	Korter	11.2	s	s	35	SV-1	siirdeõhk
3	Tehno-/majapidamisruum	10.5	15	15	40	SV-1	-15 l/s üh
4	Elutuba	24.5	22	s	35	SV-1	min. 0,7 l/s m ² , +bil.
5	Garderoob	7.6	s	5	35	SV-1	min. -3 l/s üh
6	Eesruum	10.2	10	s	35	SV-1	+bilansile
7	Aurusaun	2.5	6	6	35	SV-1	10-20 m ³ /h in
8	Soomesaun	4.3	9	9	35	SV-1	+/- 2 l/s m ²
9	Dushiruumid	2.6	s	30	35	SV-1	-15 l/s üh
10	Sahver	3.3	s	4	35	SV-1	min. -0,35 l/s m ²
11	Talveaed	20.5	20	s	35	SV-1	+1 l/s m ²
12	Köök/Söögituba	30.3	s	20	35	SV-1	-20 l/s üh
13	Koridor/Trepihall	20.0	8	s	35	SV-1	+bilansile
14	Vestibüül	9.0	7	s	35	SV-1	+bilansile
15	WC	3.7	s	10	35	SV-1	-10 l/s üh
16	Kabinet	9.4	7	s	35	SV-1	+7 l/s in, +bil.
17	Garaaž	32.6	12	12	35	SV-1	+/-0,35 l/s m ²
	KOKKU 1.KORRUS	76.9	126	126			
2.KORRUS							
17	Garderoob/Vannituba	10.0	s	15	35	SV-1	-15 l/s üh
18	Magamistuba	23.2	14	s	30	SV-1	+7 l/s in
19	Lastetuba	17.0	10	s	30	SV-1	+10 l/s in
20	Koridor/Raamatukogu	9.6	s	8	35	SV-1	-bilansile
21	Vannituba	5.8	s	15	35	SV-1	-15 l/s üh
22	Kontor/Jõusaal	17.5	14	s	35	SV-1	+7 l/s in
	KOKKU 2.KORRUS	73.4	38	38			
	KOKKU HOONES	215.0	164	164			

*s - siirdeõhk