












L1, L2, L3, N, PE		SKEEM	NIMETUS	P _i [kW]	KAITSE/ [A]	KAABEL [mm] ²	t _{rak} [S]
	RVK 8	L2	Pistikupesad ruum 202	3,0	B16	XPJ-HF 3G2,5	0,4
	RVK 9	L3	Pistikupesad ruum 206	3,0	B16	XPJ-HF 3G2,5	0,4
	RVK 10	L1	Pistikupesad ruum 205	3,0	B16	XPJ-HF 3G2,5	0,4
	RVK 11	L2	Käterätkuivatid vannitubades	2,0	B16	XPJ-HF 3G2,5	0,4
	RVK 12	L3	Reserv		B16		
	19	L1	Reserv		B6		
	L3, N	G	Generaatori pistikupesa väljas			XPJ-HF 3G4	
Ümberlülititi I-0-II							
	RVK 13	L3	Valgustus I korrus	0,9	B10	XPJ-HF 3G1,5	0,4
	RVK 14	L3	Valgustus vannitoad I ja II korrus	0,06	B10	XPJ-HF 3G1,5	0,4
	RVK 15	L3	Valgustus II korrus	0,4	B10	XPJ-HF 3G1,5	0,4
	RVK 16	L3	Külmiku pistikupesa	0,7	B16	XPJ-HF 3G2,5	0,4
	RVK 17	L3	Pistikupesad I korruse trepi all	3,0	B16	XPJ-HF 3G2,5	0,4
	25	L3	Süvaveepump	1,8	C10	MCMK 2x2,5/2,5	0,4