

TABEL 2 – ÕHUHULKADE TABEL

<i>Nõ</i>	<i>Nimetus</i>	<i>Pind m2</i>	<i>S l/s</i>	<i>V l/s</i>	<i>Norm. müra tase</i>	<i>Süsteem</i>	<i>Märkus</i>
1.KORRUS							
1	Köök/Elutuba	55.5	25	20	35	SV1	-20 l/s üh; +bilansile
2	Tuba	13.9	7	s	35	SV1	+7 l/s in
3	Koridor	8.9	8	s	35	SV1	+bilansile
4	Esik-Garderoob	10.6	s	10	35	SV1	-1 l/s m2
5	Leiliruum	4.4	9	9	35	SV1	+/- 2 l/s m2
6	Pesuruum	4.4	s	15	35	SV1	-15 l/s üh
7	Majapidamisruum	2.9	s	10	40	SV1	-3 l/s m2
8	Sauna eesruum	8.9	25	s	35	SV1	+bilansile
9	WC	2.3	s	10	35	SV1	-10 l/s üh
10	Tehnoruum	7.0	14	14	40	SV1	+/- 2 l/s m2
11	Garaaž	22.2	8	8	40	SV1	+/- 0.35 l/s m2
	KOKKU 1.KORRUS	141.0	96	96			
2.KORRUS							
12	Magamistuba	23.1	10	s	30	SV1	+10 l/s in
13	Magamistuba	21.1	10	s	30	SV1	+10 l/s in
14	Garderoob	7.8	s	8	35	SV1	-1 l/s m2
15	Koridor	11.1	s	21	35	SV1	-bilansile
16	Dushiruum	10.1	s	15	35	SV1	-15 l/s üh
17	Magamistuba	22.9	10	s	30	SV1	+10 l/s in
18	Magamistuba	20.3	14	s	30	SV1	+7 l/s in
	KOKKU 2.KORRUS	116.4	44	44			
	KOKKU HOONES	257.4	140	140			

* s - siirdeõhk