

TABEL 2 – ÕHUHULKADE TABEL

<i>Nõ</i>	<i>Nimetus</i>	<i>Pind m2</i>	<i>S l/s</i>	<i>V l/s</i>	<i>Norm. müra tase</i>	<i>Süsteem</i>	<i>Märkus</i>
B KORPUS - 1.KORRUS							
102	Vestibüül	45.9	138	s	40	SV1	+3 l/s m2
103	Koridor	90.8	91	150	40	SV1	+1 l/s m2; -bilansile
104	Kabinet	25.8	20	20	35	SV1	+/-10 l/s in. (2 inimest)
105	Arhiiv	9.6	s	20	40	SV1	-bilansile
106	Puldiruum 10/2	10.6	20	s	40	SV1	+/-10 l/s in.
107	Röntgenkabinet 10	47.0	141	188	40	SV1	+3/-4 l/s m2.
108	Kabinet	13.1	10	10	35	SV1	+/-10 l/s in.
109	Kabinet	13.1	10	10	35	SV1	+/-10 l/s in.
110	Tehnoruum	23.0	46	46	45	SV1	+/- 2 l/s m2
111	Kabinet	15.2	10	10	35	SV1	+/-10 l/s in.
112	Koridor	8.9	9	s	40	SV1	+ 1 l/s m2
113	Kabinet	15.2	20	20	35		+/-10 l/s in. (2 inimest)
114	Ruum	21.0	20	20	35		+/-10 l/s in. (2 inimest)
121	WC (personal)	5.6	s	20	40	SV1	-20 l/s üh
122	Kabinet	7.8	10	s	35	SV1	+/-10 l/s in.
123	Kabinet	23.3	20	30	35	SV1	+/-10 l/s in. (2 inimest); -bilansile
124	Kabinet	22.8	20	20	35	SV1	+/-10 l/s in. (2 inimest)
125	Kabinet	21.5	20	20	35	SV1	+/-10 l/s in. (2 inimest)
126	WC (külalised)	9.3	s	30	40	SV1	-30 l/s üh
129	Abiruum	10.5	10	10	45	SV1	+/-1 l/s m2
130.1	Hambaravi kabinet 25	10.0	20	20	35	SV1	+/-10 l/s in. (2 inimest)
130.2	Hambaravi kabinet 24	17.4	20	20	35	SV1	+/-10 l/s in. (2 inimest)

130.3	Hambaravi kabinet 23	16.0	20	20	35	SV1	+/-10 l/s in. (2 inimest)
131	Hambalabor	28.9	30	30	35	SV1	+/-10 l/s in. (3 inimest)
135	Kabinet	6.7	20	20	35	SV1	+/-10 l/s in. (2 inimest)
136	Kabinet	7.6	20	20	35	SV1	+/-10 l/s in. (2 inimest)
137	Abiruum	1.3	s	s	45	SV1	siirdeõhk
138	Abiruum	2.3	s	7	45	SV1	-3 l/s m2.
139.1	Kabinet	7.7	20	20	35	SV1	+/-10 l/s in. (2 inimest)
139.2	Kabinet	7.3	20	20	35	SV1	+/-10 l/s in. (2 inimest)
140	Koridor	26.4	26	s	40	SV1	+1 l/s m2
141	Reisimeditstiinikabinet	12.2	20	20	35	SV1	+/-10 l/s in. (2 inimest)
142	Kabinet	8.1	20	20	35	SV1	+/-10 l/s in. (2 inimest)
143	Tambur	4.2	s	5	40	SV1	-1 l/s m2
144	Abiruum	2.2	s	7	45	SV1	-3 l/s m2
145	Kabinet	11.6	27	s	35	SV1	+/-10 l/s in. (2 inimest) +bilansile
146	WC (Personal)	2.2	s	20	40	SV1	-20 l/s üh
147	Labor	19.5	48	59	35	SV1	+2/-3 l/s m2; +bilansile (abiruum)
148	Koridor	58.3	58	s	40	SV1	+1 l/s m2
149	Abiruum	3.0	s	9	45	SV1	-3 l/s m2
150	Labor	10.2	40	40	35	SV1	+/-10 l/s in. (4 inimest)
152	Kabinet	33.2	60	60	35	SV1	+ 10 l/s in (6 inimest)
153	Abiruum	12.6	13	13	45	SV1	+/-1 l/s m2
154	Hambaravi kab. 13	23.2	20	20	35	SV1	+/-10 l/s in. (2 inimest)
155	Hambaravi kab. 12	24.9	20	20	35	SV1	+/-10 l/s in. (2 inimest)
156	Trepikoda	31.0	s	43	40	SV1	-1 l/s m2; -bilansile
	KOKKU 1.KORRUS	609.9	1137	1137			
	KOKKU HOONES	609.9	1137	1137			

* s – siirdeõhk